

Product fiche

Ventilation unit: LG 350 F

	manual control	clock control	central demand control	local demand control	
Specific energy consumption (SEC)					
cold climate	-78,8	-79,9	-82,1	-86,0	[kWh/(m ² ·a)]
average climate	-37,7	-38,5	-40,1	-42,9	[kWh/(m ² ·a)]
warm climate	-14,1	-14,8	-16,0	-18,1	[kWh/(m ² ·a)]
Specific energy consumption class					
	A	A	A	A+ (most efficient)	
Type					
"residential ventilation system", "bidirectional ventilation system"					
Motor and drive					
variable speed			x-value	2	[-]
Type of heat recovery system					
recuperative					
Thermal efficiency of heat recovery			η_t	81,2%	[-]
Maximum flow rate			q_{Vd}	350	[m ³ /h]
Electric power input of the fan drive, including any motor control equipment, at maximum flow rate			P_E	93,1	[W]
Sound power level			L_{WA}	37,7	[dB(A)]
Reference flow rate			q_{Vn}	245	[m ³ /h]
Reference pressure difference			p_{tU}	50	[Pa]
Specific power input			SPI	0,17	[W/(m ³ /h)]
Ventilation control (CTRL)					
local demand control	1	0,95	0,85	0,65	[-]
Maximum air leakage rate referred to reference flow rate					
internal	q_{vi} / q_{Vn}		0,57%		
external	q_{ve} / q_{Vn}		0,78%		

Filter change

The filters are to be replaced as soon as the command to replace the filters appears on the display of the operator control unit. (marked red in the pictures alongside)

CAUTION:

If the filters are not changed regularly, the system can not work efficiently and the power consumption increases.



Operator control unit "MINI"



Operator control unit "TOUCH"

Waste disposal

Units that are no longer in working order have to be dismantled and properly disposed of by a specialized company via suitable collection centres and in compliance with the waste electrical and electronic equipment ordinance (WEEE), which provides for ratification of community law, directive 202/95/EC (RoHS) and the directive 2002/96/EC (the WEEE directive).

Annual electricity consumption (AEC)	22l	12l	12l	02l	Q&K \#m ² UQ
Annual heating saved (AHS)					
cold climate	84,2	84,7	85,9	88,3	[kWh primary energy/a]
average climate	43,0	43,3	43,9	45,1	[kWh primary energy/a]
warm climate	19,5	19,6	19,9	20,4	[kWh primary energy/a]

Information based on the current state of knowledge of EU Regulations 1253/2014 and 1254/2014

Download from: www.pichlerluft.at

Responsible for the content: J. Pichler Gesellschaft m.b.H.
Photos: Archiv J. Pichler Gesellschaft m.b.H. | Text: J. Pichler Gesellschaft m.b.H.
All rights reserved | All photos are symbolic photos | Subject to change without notice | Version: 10/2024



Systematic ventilation.

J. PICHLER
Gesellschaft m.b.H.
office@pichlerluft.at
www.pichlerluft.at

ÖSTERREICH
9021 KLAGENFURT
AM WÖRTERSEE
Karlweg 5
T +43 (0)463 32769
F +43 (0)463 37548

ÖSTERREICH
1100 WIEN
Doerenkampgasse 5
T +43 (0)1 6880988
F +43 (0)1 6880988-13

Sales offices in
Slovenia and Serbia.
Sales partners in
Germany, Switzerland
and Italy.